



NOTE

1. BACKFILL AND COMPACTION REQUIREMENTS SHALL COMPLY WITH ASH CREEK 'SSD STANDARDS.
2. CLEANOUT DIAMETER TO BE SAME AS LATERAL.
3. 6" LATERALS TO CONNECT AT MANHOLE ONLY.
4. RISER SHALL BE INSTALLED VERTICALLY PLUMB.

SEWER SERVICE CONNECTION DETAIL
N.T.S.